SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Hebbal Bangalore - 24
Mob : 9845020536, 9901920004

WORK REPORT

No.

Date :

Srinivasapura

S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	165 mm		
2.	Total Deapth of The Borewell	984'		
3.	MS Casing Erected	147'		
4.	1st Water Source at the Deapth	292'		
5.	2nd Water Source at the Deapth	498'		
6.	3rd Water Source at the Deapth	705'		
7.	4th Water Source at the Deapth	910'		
8.	If any Silt, Boulders at the Deapth	-		
9.	Nature of Water	Sweet water		
10.	Moter Pump to be Used	15 HP 35 Stage		
11.	Any other Remarks	-		
12.	Total Yield of the Borewell	2'. 3"		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

GROUND WATER SURVEY REPORT

OPEN WELL/ BOREWELL
DATA OF SURVEY

a) Name of the Party : AEE, Byatarayana pura. Sub Division

b) Location of the Site : ~~BEO~~ BBMP Ward No - 5

c) Area of the land : Srinivasa pura.

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA :

2) Recommended Site for drilling :

3) Total depth to be drilled : 900' to 1200'

4) Approx. casing pipe required : 120' to 150'

5) No. of water bearing Zones : — 1 —

6) No. of favourable spots marked : — 1 —

7) Qty. of water expected : 1½' to 2'.0

8) Method of survey carried out : GEO

9) Remarks :

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

P.T.O. : Terms & Conditions

BOREWELL SITE PLAN



Nagnely Borewell :- Drilling of Borewell & Pump & motor at Dwarakanagara Extn. Srinivasarma Talekar Palanahalli Thota Kattigenahalli Extn. in ward No-5

W. No. 5 ಶ್ರೀನಿವಾಸರೆಡ್ಡಿ ಪಲ್ಲನಹಳ್ಳಿ

AE-05
ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬ.ಬೃ.ಬೆಂ.ಮ. ವ್ಯಾ ರಾಯಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore

No. 5 ಶ್ರೀನಿವಾಸಪುರ ಮೆಗಲೂರ್

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಶ್ರೀನಿ. ಬ್ಯಾಲರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
BWSSB, Bangalore